



# Single Window Clearance System

Directorate of Industries(DOI)  
Govt. of Himachal Pradesh

39

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

## NO OBJECTION CERTIFICATE

### TO WHOM IT MAY CONCERN

That the premises of **THE ASIAN SCHOOL, VILL. KISHANPURA, PAONTA SAHIB, DISTT. SIRMOUR (H.P.)** was inspected on 2025-03-10 with reference to his application No. App/03/07/25/8/412 dated 2025-03-07 10:46:03 by the incharge Fire Station FS Paonta Sahib with regard to measures adopted for protection against fire and it has been reported/recommended

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/renewed for two years w.e.f. 24/03/2025 to 23/03/2027 subject to fulfilment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House Keeping must be maintained within the premises.

हिमाचल प्रदेश सरकार

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.**

[Digitally Signed 24-03-2025 18:05:40]  
Chief Fire Officer.  
Himachal Pradesh Shimla-2

Place: Shimla  
Dated: 2025-03-24

राजनिधि  
Chairman  
THE ASIAN SCHOOL  
BRANCH - PAONTA SAHIB  
Vill. Kishanpura, P.O. Jamniwala  
Paonta Sahib, Distt. Sirmour (H.P.)